



KEY

MAXIMUM LENGTH, 3 METRES

MATERIAL: 225x75 TREATED TIMBER

50x50x500 STAKES

NOTES

1. DO NOT SCALE FROM DRAWING.
2. ALL TIMBER SHALL BE IN ACCORDANCE WITH CLAUSES 306 & 311 OF THE MCHW AND BS EN 351-1:1996.
3. ALL METAL PARTS SHALL BE IN ACCORDANCE WITH THE APPROPRIATE CLAUSES IN THE MCHW 300 SERIES AND BS 5709:2006.
4. HANDRAILS ARE TO BE KEE KLAMP SIZE 8 OR EQUIVALENT.
5. ENDS OF BRIDGES TO BE 0 TO 75 MM ABOVE GROUND LEVEL. FOR SLOPING SITES HEIGHTS ABOVE GROUND LEVEL TO BE AGREED BY THE OVERSEEING ORGANISATION.
6. END POSTS OF HANDRAILS TO BE DRIVEN INTO BANKS.
7. IF BRIDGE IS 3 METRES OR LESS, THEN NO INTERMEDIATE UPRIGHT ON HAND-RAIL(S).
8. IF BRIDGE IS BETWEEN 3 METRES AND 4 METRES THEN ONE INTERMEDIATE UPRIGHT HANDRAIL-POST, TO BE CENTRED.
9. IF BRIDGE IS 4 METRES OR OVER THEN INTERMEDIATE UPRIGHT HANDRAIL-POSTS ARE TO BE SPACED EVENLY BETWEEN 2 AND 3 METRES APART.
10. ALL HAND-RAILS ARE TO HAVE AN INTERMEDIATE RAIL AT 1100MM HIGH FOR FOOTPATHS AND THE TOP-RAIL AT 1400MM HIGH FOR BRIDLEWAYS.
11. AN ADDITIONAL PLANK, TAKING THE WIDTH TO ONE METRE, SHALL BE INSTALLED IF REQUESTED BY THE OVERSEEING ORGANISATION.
12. HAND-RAILS ARE TO BE PROVIDED ON ONE SIDE UNLESS REQUESTED BY THE OVERSEEING ORGANISATION.

Rev	Date	Description of revision	Drawn	Checked	Review'd	Approv'd

DRAWING STATUS

APPROVED



Essex Highways, Seax House, Victoria Road South,
Chelmsford, CM1 1QH.
Tel: 0345 6037631

© Essex County Council

SCHEME TITLE

STANDARD DETAILS

DRAWING TITLE

STANDARD PEDESTRIAN PLANK
FOOTBRIDGE

DESIGNED EH	DRAWN IS	CHECKED EH/ECC	REVIEWED EH	APPROVED ECC
DATE AUG 18	DATE AUG 18	DATE FEB 19	DATE FEB 19	DATE FEB 19

DRAWING UNITS U.N.O.
DIMENSIONS IN MILLIMETRES
LEVELS IN METRES

SCALE AT A3 (420x297mm)
N.T.S

DRAWING No. ECC-SD-2600-001	REV. -
--------------------------------	-----------

